DECLARATION OF CONFORMITY



In accordance with ISO/IEC Guide 22 and EN 45014

Manufacturer's Name: Continental Control Systems, LLC

Manufacturer's 3131 Indian Rd. Address: Boulder, CO 80301

U. S. A.

Product Names: WattNode® BACnet®, WattNode® Revenue for BACnet®

Model Numbers: WNC-3Y-208-BN, WNC-3Y-400-BN, WNC-3Y-480-BN, WNC-3Y-600-BN,

WNC-3D-240-BN, WNC-3D-400-BN, WNC-3D-480-BN,

RWNC-3Y-208-BN, RWNC-3Y-400-BN, RWNC-3Y-480-BN, RWNC-3Y-600-BN,

RWNC-3D-240-BN, RWNC-3D-400-BN, RWNC-3D-480-BN

Product Options: This declaration covers all options of the product.

The product described above conforms with:

EMC:

The requirements of the European Council Directive 89/336/EEC and FCC Part 15.

EN 55011: 2007 – Class B

- FCC Part 15 Class B
- EN 61326-1:2006 Industrial Locations Electrical equipment for measurement, control, and laboratory use. This includes the following:
 - EN 61000-4-2 Electrostatic Discharge (B: self-recovering)
 - EN 61000-4-3 Radiated RF Immunity (A: no degradation)
 - EN 61000-4-4 Electrical Fast Transient/Burst (B: self-recovering)
 - EN 61000-4-5 Surge Immunity (A: no degradation)
 - EN 61000-4-6 Conducted RF Immunity (A: no degradation)
 - EN 61000-4-8 Power Frequency H-field (A: no degradation)
 - EN 61000-4-11 Voltage Dips and Interrupts (B: self-recovering)

Safety:

The requirements of the European Council Directive 73/23/EEC and 93/68/EEC Low Voltage Directive, UL, and CSA.

- EN 61010-1:2001 (2nd edition) Safety requirements for electrical equipment for measurement, control, and laboratory use.
- UL 61010-1 Standard for Safety of Electrical Equipment for Measurement, Control and Laboratory Use; Part 1: General Requirements. UL File# E312220.
- CAN/CSA-C22.2 No 61010-1-04 Canadian Standard for Safety of Electrical Equipment For Measurement, Control and Laboratory Use; Part 1: General Requirements

Boulder, Colorado, U.S.A.

August 1, 2013

Nathaniel W. Crutcher Director of Engineering

Wathand W. Contel