


NOTES:

1. DO NOT CONNECT LINE CONFIGURATIONS OTHER THAN AS SPECIFIED.
2. USE CONDUCTORS RATED FOR 600V MINIMUM.
3. FOR USE ON A SOLIDLY GROUNDED WYE SOURCE ONLY.
4. CLASS 1 CONTROL CIRCUIT: < 5V, < 1VA.
5. "CT" IS AN ABBREVIATION FOR "CURRENT TRANSFORMER".
6. FIELD WIRING TERMINALS ARE MARKED WITH A CIRCLE (○).

CURRENT TRANSFORMER CONNECTIONS
ABOVE ILLUSTRATES A TYPICAL SETUP. FROM ONE TO THREE CURRENT TRANSFORMERS MAY BE CONNECTED TO WATTNODE METER M1. CURRENT TRANSFORMERS ARE NOT PROVIDED WITH THE PANEL AND SHALL BE PROVIDED BY THE INSTALLER.

Meter Enclosure				 Continental Control Systems, LLC
DRAWING # ME1-C-1_Wiring_3Y400_RevA		NAME CAH		
PART # ME1-C-1		DATE 07/12/2018		
REVISION: A	DRAWN	CAH	07/12/2018	Socomec Group www.ctlsys.com (303) 444-7422
SHEET: 1 OF 1	CHECKED	NWC	07/12/2018	