

DECLARATION OF CONFORMITY

In accordance with ISO/IEC Guide 22 and EN 45014



Manufacturer's Name: Continental Control Systems, LLC

Manufacturer's Address: 3131 Indian Rd.
Boulder, CO 80301
U. S. A.

Product Name: *Accu-CT™*

Model Numbers: ACT-0750-xxx where xxx is the rated primary current

Product Options: This declaration covers all options of the product.

The product described above conforms to the requirements of the European Council Directive 73/23/EEC and 93/68/EEC Low Voltage Directive, UL, and CSA.

- IEC 60044-1:2003-02 (Edition 1.2) – Instrument Transformers Part 1: Current Transformers
 - Thermal and dielectric tests were conducted under UL file E325972.
 - The Accu-CT meets the class 1.0 accuracy requirements. With Option C0.6, the Accu-CT meets the class 0.5 and class 0.5 S accuracy requirements. Some options may not meet the class 1.0 accuracy limits.
 - This product is designed with an internal burden resistor to produce a standard output voltage in place of the standard output currents listed in section 4.2 and standard values of rated output in section 4.4.
- UL using IEEE Standard C57.13-1993
- CAN/CSA 60044-1
- RoHS Directive 2002/95/EC

Boulder, Colorado, U.S.A.

February 23, 2012

A handwritten signature in blue ink that reads 'Nathaniel W. Crutcher'.

Nathaniel W. Crutcher
Director of Engineering